



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers
Name and address of the applicant	Wezhou Xika Electrical Co.,Ltd No.35 Shahong Rd. Wanglin Industary Zone,Beibaixiang, Yueqing,Zhejiang Province,P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <small>Note: When more than one factory, please report on page 2</small>	Wezhou Xika Electrical Co.,Ltd No.35 Shahong Rd. Wanglin Industary Zone,Beibaixiang, Yueqing,Zhejiang Province,P.R.China
Ratings and principal characteristics	Ue= 240/415V~ (1P), 415V~ (2P, 3P, 4P) In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A Ics= Icn= 6kA; B-, C-, D- type; 50/60Hz
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	PPI
Model / Type Ref.	-
Additional information (if necessary may also be reported on page 2)	IEC 60898-1:2015
A sample of the product was tested and found to be in conformity with	190300196SHA-001
As shown in the Test Report Ref. No. which forms part of this Certificate	


This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 25 March 2022

intertek

Signature:


Henrik Wikström